

Product: Cobastat AS010001 and  
AS010002  
Supplier: Cobra Europe  
Test: Compliance with BS EN 14041  
Conclusion: "Static dissipative"  
vertical resistance  $\leq 10^9 \Omega$

Appearance



Date of test: 13<sup>th</sup> September 2019

Conditions: 50 %rh  $\pm$  5%rh 23  $\pm$  2 °C

Results:	Parameter	Result ( $\Omega$ )			Method
	Vertical resistance	(Max.)	(Min.)	(Mean)	
		$1.4 \times 10^7$	$9.5 \times 10^6$	$1.1 \times 10^7$	EN1081

Certificate No: C2019-0311-2

Full details of the trial, results and recommendations are documented in  
ESL Report No. 2019-0311

Dr Jeremy Smallwood  
Managing Director and Principal Consultant



13 Redhill Crescent, Southampton, SO16 7BQ, United Kingdom.

+44 (0)23 8090 5600 info@electrostatics.net www.electrostatics.net