


Product: Cobastat AS010001 and
AS010002
Supplier: Cobra Europe
Test: Compliance with BS EN 14041
Conclusion: "Static dissipative"
vertical resistance $\leq 10^9 \Omega$

Appearance



Date of test: 13th September 2019

Conditions: 50 %rh $\pm$ 5%rh 23 $\pm$ 2 °C

Results:	Parameter	Result (Ω)			Method
	Vertical resistance	(Max.)	(Min.)	(Mean)	
		1.4×10^7	9.5×10^6	1.1×10^7	EN1081

Certificate No: C2019-0311-2

Full details of the trial, results and recommendations are documented in
ESL Report No. 2019-0311

Dr Jeremy Smallwood
Managing Director and Principal Consultant



13 Redhill Crescent, Southampton, SO16 7BQ, United Kingdom.

+44 (0)23 8090 5600 info@electrostatics.net www.electrostatics.net